



**BILL RICHARDSON**  
GOVERNOR

*State of New Mexico*  
**ENVIRONMENT DEPARTMENT**

*Construction Programs Bureau*  
*Harold Runnels Building*  
1190 St. Francis Drive, P.O. Box 26110  
Santa Fe, New Mexico 87502-6110  
Telephone (505) 827-2806  
Fax (505) 827-2837

<http://www.nmenv.state.nm.us/cpb/cbptop.html>



**RON CURRY**  
SECRETARY

**JIM PERRY**  
ASD DIRECTOR

May 15, 2006

Mr. Adelmo Archuleta, P.E.  
President/CEO  
Molzen-Corbin & Associates  
2701 Miles Road, SE  
Albuquerque, NM 87106

**Re: Village of Ruidoso/Ruidoso Downs Joint Use Board  
PER for WWTP Upgrades**

Dear Del:

I have completed review of the Preliminary Engineering Report (PER) and have reviewed my notes from the recent Public Hearing on said document and have the following comments and recommendations:

1. Please remove all reference in the document to a 1.0 mg/l phosphorous design limit, with exception of any allusion within the executive summary and section 3.2 (History) for historical discussion only.
2. Please update the report accordingly regarding availability of the adjacent 2-acre parcel.
3. Please correct the incorrect elevations noted in the discussion of the floodplain, which is listed at approximately 4100 feet above msl (should be 6100 +/- feet above msl).

Please make the above adjustments to the document and resubmit for final approval and filing at your earliest convenience.

Feel free to call me should you have any questions regarding the above comments.

Sincerely,

  
Jim Chiasson, P.E.  
Technical Section Manager

cc: Lori McKnight, Village of Ruidoso  
John Waters, City of Ruidoso Downs  
Project File